

Lake Hemet Municipal Water
District

Water Quality Reports for 2025

Final Reports for

Valle Vista/East Hemet

Garner Valley

Lake Hemet Campground

2025 Water Quality Report for Lake Hemet Municipal Water District

ESTE INFORME CONTIENE INFORMACIÓN MUY IMPORTANTE SOBRE SU AGUA PARA BEBER. FAVOR DE COMUNICARSE LAKE HEMET MWD PARA ASISTIRLO EN ESPAÑOL A 951-658-3241.

We test the drinking water for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1-December 31, 2025, and may include earlier data. LHMWD invites public participation at our monthly board meeting held at 3:00 PM on the third Thursday of every month at the LHMWD district office, 26385 Fairview Ave. Hemet, 92544. For more information contact Kristen Frankforter, 951-658-3241 ext.245 or email kfrankforter@lhmwd.org.



There are ten wells located along the San Jacinto River from Valle Vista to San Jacinto that supply most of your drinking water. Complete drinking water source assessments (2002, 2014, 2022) for all ten wells and our 2022 Sanitary Survey are available upon request at our district office located at 26385 Fairview Ave. Hemet, CA 92544 (951-658-3241) or from the State Water Resources Control Board, Drinking Water Field Office, 2375 Northside Drive, Suite 100, San Diego, CA 92108 (619-525-4159). The assessments determined our sources are most vulnerable to sewer collection systems, septic systems, agricultural and/or irrigation wells, and high-density housing. Lake Hemet MWD treats all its ground water sources with chlorine disinfectant, either in liquid or tablet form. This is the only treatment added to the water we provide. There are two tie-ins to Eastern Municipal Water District (EMWD) water, which also comes from local ground water sources and is treated similarly. In 2025, 2.9% of domestic demand was purchased from EMWD.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised people such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by Cryptosporidium and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

To ensure that tap water is safe to drink, the USEPA and the State Water Board prescribe regulations that limit the amount of certain contaminants in water provided by public water systems. U.S. Food and Drug Administration regulations and California Law also establish limits for contaminants in bottled water that provide the same protection for public health.

The Sources of drinking water (both tap and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791).

Contaminants that may be present in source water include: **Radioactive contaminants** that can be naturally-occurring or be the result of oil and gas production or mining activities; **Microbial contaminants**, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife; **Inorganic contaminants**, such as salts and metals, that can be naturally-occurring or result from urban storm-water runoff, industrial or domestic wastewater discharges, oil and gas production, mining or farming; **Pesticides and herbicides** that may come from a variety of sources such as agriculture, urban storm-water runoff and residential uses; **Organic chemical contaminants**, including synthetic and volatile organic chemicals that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban storm-water runoff, agricultural applications, and septic systems.

Unregulated contaminant monitoring helps USEPA and the State Board to determine where certain contaminants occur and whether the contaminants need to be regulated.

Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of skin. Nitrate levels above 10 mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider.

While your drinking water meets the federal and state standard for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs of removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. LHMWD is responsible for providing high quality drinking water and removing lead pipes but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Kristen Frankforter at LHMWD, 951-658-3241 ext. 245. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline or at <http://www.epa.gov/safewater/lead>. LHMWD has a lead service line inventory that can be accessed through our website www.lhmwd.org under the "about us" tab on the "water quality" page.

Terms and Abbreviations used in this report

Maximum Contaminant Level (MCL): The highest level of contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHGs (or MCLGs) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): The level of contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the U.S. Environmental Protection Agency (USEPA).

Public Health Goal (PHG): The level of contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Primary Drinking Water Standard (PDWS): MCLs, MRDLs and treatment techniques (TTs) for contaminants that affect health, along with their monitoring and reporting requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor, or appearance of drinking water. Contaminants with SDWSs do not affect health at MCL levels.

Maximum Residual Disinfectant Level (MRDL): The highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Mg/L: milligrams per liter; also ppm or parts per million is another expression of same value.

Regulatory Action Level (AL): The concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

ND: Not detectable at testing limit

NTU: Nephelometric Turbidity Unit: a measure of turbidity

Parts per Billion (ppb): micrograms per liter ($\mu\text{g/L}$) is approximately one second in 32 years.

Parts per Million (ppm): milligrams per liter (mg/L) is approximate to about one second in 11.5 days,


Parts per Trillion (ppt): nanograms per liter (ng/L) is approximate to about three seconds in 100,000 years.

Parts per Quadrillion (ppq): picograms per liter (pg/L) is approximately 2.5 minutes in the total age of the earth or 2.5 billion years.

Picocuries per liter (pCi/L): a measure of radiation

Microsiemens per centimeter ($\mu\text{S/cm}$): a measure of conductivity

Level 1 Assessment: A study of the water system to identify potential problems and determine (if possible) why total coliform bacteria have been found in our water system.



The following tables list all the drinking water contaminants that were detected during the most recent sampling. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, although representative of the water quality, are more than one year old.

Results for water purchased from Eastern Municipal Water District (EMWD) are listed in braces {} in the tables below.

SAMPLING RESULTS FOR THE DETECTION OF COLIFORM BACTERIA

Microbiological Contaminants	Sample Date	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical source of Bacteria
E. coli	2025	(in the year) 0	0	0	0	Human and animal fecal waste

SAMPLING RESULTS FOR LEAD AND COPPER

Lead and Copper	Sample Date	No. samples collected	90 th percentile level detected	No. sites exceeding AL	AL	PHG	Typical source of contaminant
Lead (ppb)	2025	37	ND	Zero	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (mg/L)	2025	37	0.408	Zero	1.3	0.3	Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives

SAMPLING RESULTS FOR SODIUM AND HARDNESS

Chemical or Constituent	Sample Date	Level Detected {EMWD}	Range of Detections {EMWD}	MCL	PHG	Typical Source of Contaminant
Sodium (ppm)	2024-25	36 {44}	19-102 {23-93}	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2024-25	154 {162}	59-296 {92-256}	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

SAMPLING RESULTS FOR UNREGULATED CONTAMINANTS

Contaminant	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
Total Organic Carbon [TOC] (ppm)	2025	0.64 {0.5}	ND- 1.3 {ND-1.4}	---	---
Vanadium (ppb)	2023-25	13	3.8-77	50	Exposures resulted in developmental and reproductive effects in rats

SAMPLING RESULTS FOR CONTAMINANTS WITH A SECONDARY DRINKING WATER STANDARD					
Contaminant (reporting units)	Date	Average Level Detected {EMWD}	Range of Detections {EMWD}	SMCL	Typical Source of Contaminant
Chloride (mg/L)	2024-25	25 {36}	14-53 {10-102}	500 mg/L	Runoff/leaching from natural deposits
Odor-Threshold – distribution (TON)	2025	1	1	3	Natural-occurring organic deposits
Odor-Threshold – source water (TON)	2023-25	0.9 {1}	ND-1 {1->6}	3	Natural-occurring organic deposits
Specific Conductance (µS/cm)	2024-25	479 {510}	320-823 {304-903}	1600	Substances that form ions when in water
Sulfate (ppm)	2024-25	45 {64}	16.7-215 {11-184}	500	Runoff/leaching from natural deposits
Total Dissolved Solids [TDS] (ppm)	2024-25	299 {309}	206-542 {176-594}	1000	Runoff/leaching from natural deposits
Turbidity – distribution (NTU)	2025	0.14	ND-1.9	5	Soil runoff
Turbidity-source water (NTU)	2023-25	0.31 {0.4}	ND-0.77 {ND-1.6}	5	Soil runoff

SAMPLING RESULTS FOR CONTAMINANTS WITH A PRIMARY DRINKING WATER STANDARD						
Contaminant (reporting units)	Sample Date	Average Level Detected {EMWD}	Range of Detections {EMWD}	MCL [MRDL]	PHG [MRDLG]	Typical Source of Contaminant
Arsenic (ppb)	2023-25	ND {2.6}	ND – 7.8 {ND-5.2}	10	0.004	Erosion of natural deposits; orchard run-off
Barium (ppb)	2023-25	ND {ND}	ND - 0.16 {ND-0.14}	1	2	Erosion of natural deposits
Fluoride (ppm)	2025	0.2 {0.2}	ND - 0.58 {0.1-0.4}	2	1	Erosion of natural deposits; discharge from fertilizer factories
Gross alpha particle activity (pCi/L)	2016-24 {2023}	ND {3.5}	ND –3.9 {ND-10.6}	15	MCLG 0	Erosion of natural deposits
Hexavalent Chromium (ppb)	2025	0.4 {0.3}	ND-1.8 {0.2-0.4}	10	0.02	Erosion of natural deposits; transformation of naturally occurring trivalent chromium to hexavalent chromium by natural processes.
Nitrate (as Nitrogen) (ppm)	2025	2.2 {1.2}	0.6-4.8 {ND-4.8}	10	10	Runoff/leaching from fertilizer use, septic tanks, and sewage; erosion of natural deposits
Selenium (ppb)	2023-24	1.3 {ND}	ND-7.6 {ND-16}	50	30	Discharge from petroleum, glass & metal refineries; erosion of natural deposits; runoff from livestock lots (feed additive)
Uranium (pCi/L)	2016-24	3.0 {2.4}	ND – 5.6 {ND-6.6}	20	0.43	Erosion of natural deposits
Chlorine (ppm)	2025	1.43	0.6-3.1	[4 as Cl ₂]	[4 as Cl ₂]	Drinking water disinfectant added for treatment
Haloacetic Acids (ppb)	2025	6.0	ND-6.0	60		Byproduct of drinking water disinfection
Trihalomethanes (ppb)	2025	36.1	2.5-36.1	80		Byproduct of drinking water disinfection

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

MONITORING REQUIREMENTS NOT MET FOR LAKE HEMET MWD

Our water system failed to monitor as required for drinking water standards during 2023 and, therefore, was in violation of the regulations. Even though this failure was not an emergency, as our customers, you have a right to know what you should do, what happened, and what we did to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2023, we failed to monitor the majority of our wells select radionuclides, and one well, Well 9, for synthetic organic chemicals (SOCs) and therefore, cannot be sure of the quality of our drinking water during that time.

What should I do?

- There is nothing you need to do at this time.
- The table below lists the contaminant(s) we did not properly test for, how many samples we are required to take and how often, how many samples we took, when samples should have been taken, and the date on which follow-up samples were taken.

Contaminant	Required Sampling Frequency	Number of Samples Taken	When All Samples Should Have Been Taken	When Samples Will Be Taken
SOCs*	Every 3 years	None	2023	June 2026
Uranium	Every 9 years	None	2023	June 2026
Radium-226	Every 9 years	None	2023	June 2026

*For Well 9 only SOC: Ethylene Dibromide, Dibromochloropropane, 1,2,3-Trichloropropane, Endrin, Lindane, Methoxychlor, Toxaphene, Chlordane, Heptachlor, Heptachlor Epoxide, Hexachlorobenzene, Hexachlorocyclopentadiene, Polychlorinated Biphenyls (PCBs), Alachlor, Atrazine, Benzo(a)pyrene, Diethylhexylphthalate, Di(2-ethylhexyl) adipate, Molinate, Simazine, Thiobencarb, Oxamyl, Carbofuran, Glyphosate, Endothall, Diquat, 2,3,7,8-TCDD, 2,4-D, 2,4,5-TP (Silvex), Bentazon, Dalapon, Dinoseb, Pentachlorophenol, Picloram

If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

Lake Hemet MWD failed to monitor the wells as required for drinking water standards as directed by the Division of Drinking Water. We have since taken the required samples, as described in the last column of the table above. The samples showed we are meeting drinking water standards.

For more information, please contact Kristen Frankforter at 951-648-3241 or kfrankforter@lhmwd.org.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- **SCHOOLS:** Must notify school employees, students, and parents (if the students are minors).
- **RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS** (including nursing homes and care facilities): Must notify tenants.
- **BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS:** Must notify employees of businesses located on the property.

This notice is being sent to you by Lake Hemet Municipal Water District

State Water System ID#: CA3310022

Date distributed: June 30, 2026



2025 Consumer Confidence Report

LAKE HEMET MUNICIPAL WATER DISTRICT-GARNER VALLEY SYSTEM

Lake Hemet MWD- Garner Valley System

26385 Fairview Ave.

P.O. Box 5039

Hemet CA 92544

Phone: 951-658-3241

Fax: 951766-7031

E-mail: kfrankforter@lhmw.org

Lake Hemet MWD- Garner Valley



Resources Control Board Drinking Water Field Office, San Diego (619-525-4159). Assessments determined sources are most vulnerable to animal operations, low-density septic systems and historic waste/dump landfills.

LHMWD invites public participation at our

monthly board meeting held at 3:00 PM on the third Thursday of every month at the LHMWD district office, 26385 Fairview Avenue Hemet, CA 92544.

For more information contact Kristen Frankforter, 951-658-3241 ext. 245 or email kfrankforter@lhmw.org.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2025, and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse LHMWD a 951-658-3241 para asistirlo en español.

There are six wells located throughout Garner Valley that supply your drinking water. Drinking water source assessment (2002, 2007, 2010) and sanitary survey (2025) information is available on request from LHMWD (951-658-3241) or State Water

Protection of drinking water is everyone's responsibility. You can help protect your community's drinking water sources in several ways:

- Eliminate excessive use of lawn and garden fertilizers and pesticides- they contain hazardous chemicals that can reach your drinking water source.
- Pick up after your pets.
- If you have your own septic system, properly maintain your system to reduce leaching to water sources.
- Dispose of chemicals properly; take used motor oil to a recycling center.
- Volunteer in your community. Find a watershed or wellhead protection organization and volunteer to help. If there are no active groups, consider starting one. Use USEPA's Watershed Information Network to locate groups in your community or see How to Start a Watershed Team.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, that can be naturally occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges,

oil and gas production, mining, or farming.

Pesticides and herbicides that may come from a variety of sources such as agriculture, urban stormwater runoff, and residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals that are by-

products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural applications, and septic systems.

Radioactive contaminants that can be naturally occurring or be the result of oil and gas production and mining activities.

In order to ensure that tap water is safe to drink,

- THE USEPA AND THE STATE WATER RESOURCES CONTROL BOARD (STATE BOARD) PRESCRIBE REGULATIONS THAT LIMIT THE AMOUNT OF CERTAIN CONTAMINANTS IN WATER PROVIDED BY PUBLIC WATER SYSTEMS. U.S. FOOD AND DRUG ADMINISTRATION REGULATIONS AND CALIFORNIA LAW ALSO ESTABLISH LIMITS FOR CONTAMINANTS IN BOTTLED WATER THAT PROVIDE THE SAME PROTECTION FOR PUBLIC HEALTH.

The following tables list all the drinking water contaminants that were detected

during the most recent sampling. The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor for certain contaminants less than once per year

because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.



2025 Consumer Confidence Report

Terms used in this report

Maximum Contaminant Level (MCL): the highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHG (or MCLG) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the USEPA.

Public Health Goal (PHG): the level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfection Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs and treatment techniques (TTs) for contaminants that affect health along with their monitoring, reporting, and water treatment requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor or appearance of the drinking water. Contaminants with SDWSs do not affect health at the MCL levels.

Regulatory Action Level (AL): the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

ND: not detectable at testing limit
ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter ($\mu\text{g/L}$)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or pictograms per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

$\mu\text{S/cm}$: microsiemens per centimeter (a measure of conductivity)

NTU: Nephelometric Turbidity Unit: a measure of turbidity

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

USEPA'S
SAFE DRINKING WATER
HOTLINE
1-800-426-4791

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline: 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

Nitrate in drinking water at levels above 10 mg/L is a health risk for infants of less than six months of age. Such nitrate levels in drinking water can interfere with the capacity of the infant's blood to carry oxygen, resulting in a serious illness; symptoms include shortness of breath and blueness of the skin. Nitrate levels above 10mg/L may also affect the ability of the blood to carry oxygen in other individuals, such as pregnant women and those with certain specific enzyme deficiencies. If you are caring for an infant, or you are pregnant, you should ask advice from your health care provider. Nitrate levels may rise quickly for short periods of time because of rainfall or agricultural activity.

While your drinking water meets federal and state standards for arsenic, it does contain low levels of arsenic. The arsenic standard balances the current understanding of arsenic's possible health effects against the costs for removing arsenic from drinking water. The U.S. Environmental Protection Agency continues to research the health effects of low levels of arsenic, which is a mineral known to cause cancer in humans at high concentrations and is linked to other health effects such as skin damage and circulatory problems.

Sampling Results for Coliform Bacteria

Microbiological Contaminants	Sample Date	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical source of Bacteria
Total Coliform Bacteria	2025	(in a month) Zero	Zero	TT	0	Naturally present in environment
<i>E. coli</i>	2025	(in the year) Zero	Zero	0	0	Human and animal fecal waste

Sampling Results for Lead and Copper

Lead and Copper	Sample Date	No. of samples collected	90th percentile level detected	No. sites exceeding AL	AL	PHG	Typical source of contaminant
Lead (ppb)	2023	10	ND	Zero	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	2023	10	0.61	Zero	1.3	0.3	Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives

Sampling Results for Sodium and Hardness

Chemical or Constituent	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2023	73.6	32-97	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2023	79.8	6.8-170	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and are usually naturally occurring

Detection of Unregulated Contaminants

Chemical or Constituent (reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
Vanadium (ppb)	2023	0.7	ND-3.4	50	Exposures resulted in developmental and reproductive effects in rats.
Boron (ppm)	2023	0.03	ND-0.15	1	Exposures resulted in decreased fetal weight in newborn rats.

Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG [MRDLG]	Typical Source of Contaminant
Arsenic (ppm)	2023-25	0.7	ND-9.0	10	0.004	Erosion of natural deposits
Barium (ppm)	2023	ND	ND-0.11	1	2	Erosion of natural deposits
Hexavalent Chromium (ppb)	2025	0.1	ND-0.27	10	0.02	Erosion of natural deposits
Fluoride (ppm)	2023	0.3	0.2-0.6	2	1	Erosion of natural deposits
Gross alpha particle activity (pCi/L)	2023-25	ND	ND-3.0	15	(0)	Erosion of natural deposits
Nitrate as Nitrogen (ppm)	2025	1.6	ND-9.4	10	10	Runoff /leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Radium-228 (pCi/L)	2023-25	ND	-0.2-0.9	5 (R ₂₂₆ + R ₂₂₈)	0.019	Erosion of natural deposits
Chlorine Residual (ppm)	2025	1.3	0.9-1.8	[4.0 as Cl ₂]	[4.0 as Cl ₂]	Drinking water disinfectant added for treatment
Uranium (pCi/L)	2023-25	ND	ND-3.3	20	0.43	Byproduct of drinking water disinfection

Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	Typical Source of Contaminant
Chloride (ppm)	2023	26.6	24-31	500	Runoff/leaching from natural deposits; seawater influence
Iron (ppb)	2023-25	103	ND-660	300	Leaching from natural deposits; Industrial wastes
Odor—Threshold (distribution) (units)	2025	1	1	3	Naturally occurring organic materials
Odor—Threshold (source) (units)	2023	0.8	ND-1	3	Naturally occurring organic materials
Specific Conductance (µS/cm)	2023	486	420-580	1600	Substances that form ions when in water
Sulfate (ppm)	2023	46.2	19-82	500	Runoff /leaching from natural deposits
Total Dissolved Solids (ppm)	2023	288	250-340	1000	Runoff /leaching from natural deposits
Turbidity (distribution) (NTU)	2025	0.09	ND-0.4	5	Soil runoff
Turbidity (source) (NTU)	2023	0.26	0.12-0.48	5	Soil runoff
Zinc (ppm)	2023	ND	ND-0.21	5.0	Runoff; leaching from natural deposits

•Lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. LHMWD is responsible for providing high quality drinking water and removing lead pipes, but cannot control the variety of materials used in plumbing components in your home. You share the responsibility for protecting yourself and your family from the lead in your home plumbing. You can take responsibility by identifying and removing lead materials within your home plumbing and taking steps to reduce your family's risk. Before drinking tap water, flush your pipes for several minutes by running your tap, taking a shower, doing laundry or a load of dishes. You can also use a filter certified by an American National Standards Institute accredited certifier to reduce lead in drinking water. If you are concerned about lead in your water and wish to have your water tested, contact Kristen Frankforter at kfrankforter@lhmd.org. Information on lead in drinking water, testing methods, and steps you can take to minimize exposure is available at <http://www.epa.gov/safewater/lead>. Lake Hemet MWD's lead service line inventory can be accessed at lead-service-line-inventory-1-lhmd.hub.arcgis.com.

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

MONITORING REQUIREMENTS NOT MET FOR LAKE HEMET MWD GARNER VALLEY

Our water system failed to monitor as required for drinking water standards during 2023 and, therefore, was in violation of the regulations. Even though this failure was not an emergency, as our customers, you have a right to know what you should do, what happened, and what we did to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2023, we failed to monitor the wells for select radionuclides and therefore, cannot be sure of the quality of our drinking water during that time.

What should I do?

- There is nothing you need to do at this time.
- The table below lists the contaminant(s) we did not properly test for, how many samples we are required to take and how often, how many samples we took, when samples should have been taken, and the date on which follow-up samples were taken.

Contaminant	Required Sampling Frequency	Number of Samples Taken	When All Samples Should Have Been Taken	When Samples Were Taken
Uranium	Every 9 years	None	2023	2025
Radium-226	Every 9 years	None	2023	2025

- If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

Lake Hemet MWD failed to monitor the wells as required for drinking water standards as directed by the Division of Drinking Water. We have since taken the required samples, as described in the last column of the table above. The samples showed we are meeting drinking water standards.

For more information, please contact Kristen Frankforter at 951-648-3241 or kfrankforter@lhmwd.org.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- SCHOOLS: Must notify school employees, students, and parents (if the students are minors).
- RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.
- BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees of businesses located on the property.

This notice is being sent to you by Lake Hemet Municipal Water District

State Water System ID#: CA3310080

Date distributed: June 29, 2026



2025 Consumer Confidence Report

LAKE HEMET MUNICIPAL WATER DISTRICT CAMPGROUND SYSTEM 3310080

951-658-3241

Lake Hemet MWD Campground



We test the drinking water quality for many constituents as required by state and federal regulations. This report shows the results of our monitoring for the period of January 1 - December 31, 2025, and may include earlier monitoring data.

Este informe contiene información muy importante sobre su agua para beber. Favor de comunicarse LHMWD a 951-658-3241 para asistirlo en español.

There is one well located in the pasture just east of Lake Hemet that supplies your drinking water. Drinking water source assessment (2002) and sanitary survey (2025) information are available on request from LHMWD— 26385 Fairview Ave Hemet, CA 92544 (951-658-3241) or State Water Resources Control Board

Drinking Water Field Office, 2375 Northside Drive, Suite 100, San Diego, CA 92108 (619-525-4159). The drinking water source assessment determined that the source water is most vulnerable to contamination by animal grazing in the area.

LHMWD invites public participation at our monthly board meeting held at 3:00 PM on the third Thursday of every month at the LHMWD district office, 26385 Fairview Avenue Hemet, CA 92544.

For more information contact Kristen Frankforter, 951-658-3241 ext. 245 or email kfrankforter@lhmwd.org.

The sources of drinking water (both tap water and bottled water) include rivers, lakes, streams, ponds, reservoirs, springs and wells. As water travels over the surface of the land or through the ground, it dissolves naturally occurring minerals and, in some cases, radioactive material, and can pick up substances resulting from the presence of animals or from human activity.

In order to ensure that tap water is safe to drink,

- THE USEPA AND THE STATE WATER RESOURCES CONTROL BOARD (STATE BOARD) PRESCRIBE REGULATIONS THAT LIMIT THE AMOUNT OF CERTAIN CONTAMINANTS IN WATER PROVIDED BY PUBLIC WATER SYSTEMS. THE U.S. FOOD AND DRUG ADMINISTRATION REGULATIONS AND CALIFORNIA LAW ALSO ESTABLISH LIMITS FOR CONTAMINANTS IN BOTTLED WATER THAT PROVIDE THE SAME PROTECTION FOR PUBLIC HEALTH. ADDITIONAL INFORMATION ON BOTTLED WATER IS AVAILABLE ON THE CALIFORNIA DEPARTMENT OF PUBLIC HEALTH WEBSITE: <https://www.cdph.ca.gov/Programs/CEH/DFDCS/Pages/FDBPrograms/FoodSafetyProgram/Water.aspx>

The following tables list all the drinking water contaminants that were detected during the most recent sampling.

The presence of these contaminants in the water does not necessarily indicate that the water poses a health risk. The State Board allows us to monitor certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of the data, though representative of the water quality, are more than one year old.

Contaminants that may be present in source water include:

Microbial contaminants, such as viruses and bacteria that may come from sewage treatment plants, septic systems, agricultural livestock operations and wildlife.

Inorganic contaminants, such as salts and metals, that can be naturally

occurring or result from urban stormwater runoff, industrial or domestic wastewater discharges, oil and gas production, mining, or farming.

Pesticides and herbicides that may come from a variety of sources such as agriculture, urban stormwater runoff, and

residential uses.

Organic chemical contaminants, including synthetic and volatile organic chemicals that are by-products of industrial processes and petroleum production, and can also come from gas stations, urban stormwater runoff, agricultural applications,

and septic systems.

Radioactive contaminants that can be naturally occurring or be the result of oil and gas production and mining activities.



2025 Water Quality Report

Terms used in this report

Maximum Contaminant Level (MCL): the highest level of a contaminant that is allowed in drinking water. Primary MCLs are set as close to the PHG (or MCLG) as is economically and technologically feasible. Secondary MCLs are set to protect the odor, taste, and appearance of drinking water.

Maximum Contaminant Level Goal (MCLG): the level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs are set by the USEPA.

Public Health Goal (PHG): the level of a contaminant in drinking water below which there is no known or expected risk to health. PHGs are set by the California Environmental Protection Agency.

Maximum Residual Disinfectant Level (MRDL): the highest level of a disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Maximum Residual Disinfection Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health.

MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Primary Drinking Water Standards (PDWS): MCLs and MRDLs and treatment techniques (TTs) for contaminants that affect health along with their monitoring and reporting requirements.

Secondary Drinking Water Standards (SDWS): MCLs for contaminants that affect taste, odor or appearance of the drinking water. Contaminants with SDWSs do not affect health at the MCL levels.

Regulatory Action Level (AL): the concentration of a contaminant which, if exceeded, triggers treatment or other requirements that a water system must follow.

Treatment Technique (TT): a required process intended to reduce the level of a contaminant in drinking water.

ND: not detectable at testing limit

ppm: parts per million or milligrams per liter (mg/L)

ppb: parts per billion or micrograms per liter ($\mu\text{g/L}$)

ppt: parts per trillion or nanograms per liter (ng/L)

ppq: parts per quadrillion or picograms per liter (pg/L)

pCi/L: picocuries per liter (a measure of radiation)

$\mu\text{S/cm}$: microsiemens per centimeter (a measure of conductivity)

NTU: Nephelometric Turbidity Unit: a measure of turbidity

**USEPA'S SAFE DRINKING
WATER HOTLINE
1-800-426-4791**

Additional General Information on Drinking Water

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that the water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline: 1-800-426-4791.

Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/Centers for Disease Control (CDC) guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the Safe Drinking Water Hotline (1-800-426-4791).

If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. Lake Hemet MWD is responsible for providing high quality drinking water but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead exposure by flushing your tap for 30 seconds to 2 minutes before using water for drinking or cooking. If you do so, you may want to collect the flushed water and reuse it for another beneficial purpose, such as watering plants. If you are concerned about lead in your water, you may wish to have your water tested. Information of lead in drinking water, testing methods, and steps you can take to minimize exposure is available from the Safe Drinking Water Hotline (1-800-426-4791) or at www.epa.gov/lead.

Sampling Results for Coliform Bacteria

Microbiological Contaminants	Sample Date	Highest No. of Detections	No. of months in violation	MCL	MCLG	Typical source of Bacteria
Total Coliform Bacteria	2025	(in a month) Zero	Zero	TT	0	Naturally present in environment
<i>E. coli</i>	2025	(in the year) Zero	Zero	0	0	Human and animal fecal waste

Sampling Results for Lead and Copper

Lead and Copper	Sample Date	No. of samples collected	90th percentile level detected	No. sites exceeding AL	AL	PHG	Typical source of contaminant
Lead (ppb)	2024	5	ND	Zero	15	0.2	Internal corrosion of household water plumbing systems; discharges from industrial manufacturers; erosion of natural deposits
Copper (ppm)	2024	5	0.348	Zero	1.3	0.3	Internal corrosion of household water plumbing systems; erosion of natural deposits; leaching from wood preservatives

Detection of Unregulated Contaminants

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	Notification Level	Health Effects
Vanadium (ppb)	2023	5.1	5.1	50	Exposures resulted in developmental and reproductive effects in rats.

Sampling Results for Sodium and Hardness

Chemical or constituent	Sample Date	Level Detected	Range of Detections	MCL	PHG (MCLG)	Typical Source of Contaminant
Sodium (ppm)	2023	27	27	None	None	Salt present in the water and is generally naturally occurring
Hardness (ppm)	2023	120	120	None	None	Sum of polyvalent cations present in the water, generally magnesium and calcium, and is usually naturally occurring

Detection of Contaminants with a Primary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	MCL [MRDL]	PHG (MCLG) [MRDLG]	Typical Source of Contaminant
Barium (ppm)	2023	0.18	0.18	1	2	Discharges of oil drilling wastes; erosion of natural deposits
Chlorine residual (ppm)	2025	1.37	0.8-1.9	[4.0 as Cl ₂]	[4.0 as Cl ₂]	Drinking water disinfectant added for treatment
Fluoride (ppm)	2023	0.15	0.15	2	1	Erosion of natural deposits
Nitrate as Nitrogen (ppm)	2025	2.0	2.0	10	10	Run-off and leaching from fertilizer use; leaching from septic tanks and sewage; erosion of natural deposits
Hexavalent Chromium (ppb)	2025	0.56	0.51-0.6	10	0.02	Erosion of natural deposits; transformation of naturally occurring trivalent chromium to hexavalent chromium by natural processes

Detection of Contaminants with a Secondary Drinking Water Standard

Chemical or Constituent (and reporting units)	Sample Date	Level Detected	Range of Detections	SMCL	PHG (MCLG)	Typical Source of Contaminant
Turbidity-distribution (NTU)	2025	0.2	ND-0.5	5		Soil run-off
Odor-Threshold-distribution (units)	2025	1	1	3		Naturally occurring organic materials
Turbidity-source water (NTU)	2023	0.19	0.19	5		Soil run-off
Odor-Threshold-source water (units)	2023	1	1	3		Naturally occurring organic materials
Chloride (ppm)	2023	13	13	500		Runoff/leaching from natural deposits;
Sulfate (ppm)	2023	9.3	9.3	500		Runoff/leaching from natural deposits; industrial waste
Total Dissolved Solids (ppm)	2023	190	190	1000		Runoff/leaching from natural deposits
Specific Conductance (µS/cm)	2023	350	350	1600		Substances that form ions when in water; seawater influence

IMPORTANT INFORMATION ABOUT YOUR DRINKING WATER

Este informe contiene información muy importante sobre su agua potable. Tradúzcalo o hable con alguien que lo entienda bien.

MONITORING REQUIREMENTS NOT MET FOR LAKE HEMET MWD CAMPGROUND

Our water system failed to monitor as required for drinking water standards during the 2020 – 2022 monitoring period and, therefore, was in violation of the regulations. Even though this failure was not an emergency, as our customers, you have a right to know what you should do, what happened, and what we did to correct this situation.

We are required to monitor your drinking water for specific contaminants on a regular basis. Results of regular monitoring are an indicator of whether or not our drinking water meets health standards. During 2021, we failed to monitor the well for volatile organic chemicals (VOCs), synthetic organic chemicals (SOCs), and select radionuclides and therefore, cannot be sure of the quality of our drinking water during that time.

What should I do?

- There is nothing you need to do at this time.
- The table below lists the contaminant(s) we did not properly test for during 2021 and 2022, how many samples we are required to take and how often, how many samples we took, when samples should have been taken, and the date on which follow-up samples were taken.

Contaminant	Required Sampling Frequency	Number of Samples Taken	When All Samples Should Have Been Taken	When Samples Were or Will Be Taken
VOCs*	Every 3 years	None	2021	August 2024
SOCs**	Every 3 years	None	2021	January & April 2026
Uranium	Every 9 years	None	2022	January 2026
Radium-226	Every 9 years	None	2022	January 2026

*VOCs: Vinyl Chloride, Trichlorofluoromethane (Freon 11), 1,1-Dichloroethylene, 1,1,2-Trichloro-1,2,2-Trifluoroethane, Dichloromethane, trans-1,2-Dichloroethylene, Methyl tert-Butyl Ether, 1,1-Dichloroethane, cis-1,2-Dichloroethylene, Chloroform, Carbon Tetrachloride, 1,1,1-Trichloroethane, Benzene, 1,2-Dichloroethane, Trichloroethylene, 1,2-Dichloropropane, Bromodichloromethane, Toluene, Tetrachloroethylene, 1,1,2-Trichloroethane, Dibromochloromethane, Chlorobenzene, Ethyl Benzene, m,p-Xylene, cis-1,3-Dichloropropene, trans-1,3-Dichloropropene, o-Xylene, Styrene, Bromoform, 1,1,2,2-Tetrachloroethane, 1,4-Dichlorobenzene, 1,2-Dichlorobenzene, 1,2,4-Trichlorobenzene, Total 1,3-Dichloropropene, Total Trihalomethanes, Total Xylenes

**SOCs: Ethylene Dibromide, Dibromochloropropane, 1,2,3-Trichloropropane, Endrin, Lindane, Methoxychlor, Toxaphene, Chlordane, Heptachlor, Heptachlor Epoxide, Hexachlorobenzene, Hexachlorocyclopentadiene, Polychlorinated Biphenyls (PCBs), Alachlor, Atrazine, Benzo(a)pyrene, Diethylhexylphthalate, Di(2-ethylhexyl) adipate, Molinate, Simazine, Thiobencarb, Oxamyl, Carbofuran, Glyphosate, Endothall, Diquat, 2,3,7,8-TCDD, 2,4-D, 2,4,5-TP (Silvex), Bentazon, Dalapon, Dinoseb, Pentachlorophenol, Picloram

- If you have health issues concerning the consumption of this water, you may wish to consult your doctor.

What happened? What is being done?

Lake Hemet MWD failed to monitor the well as required for drinking water standards during the 2020 – 2022 monitoring period. We have since taken the required samples, as described in the last column of the table above. The samples showed we are meeting drinking water standards.

For more information, please contact Kristen Frankforter at 951-648-3241 or kfrankforter@lhmwd.org.

Please share this information with all the other people who drink this water, especially those who may not have received this notice directly (for example, people in apartments, nursing homes, schools, and businesses). You can do this by posting this public notice in a public place or distributing copies by hand or mail.

Secondary Notification Requirements

Upon receipt of notification from a person operating a public water system, the following notification must be given within 10 days [Health and Safety Code Section 116450(g)]:

- SCHOOLS: Must notify school employees, students, and parents (if the students are minors).
- RESIDENTIAL RENTAL PROPERTY OWNERS OR MANAGERS (including nursing homes and care facilities): Must notify tenants.
- BUSINESS PROPERTY OWNERS, MANAGERS, OR OPERATORS: Must notify employees of businesses located on the property.

This notice is being sent to you by Lake Hemet Municipal Water District

State Water System ID#: CA3310080

Date distributed: June 29, 2026